



PREVENTATIVE MAINTENANCE SCHEDULE

INTERIOR EQUIPMENT / PREVENTATIVE MAINTENANCE

ITEMS CHECKED

<u>Upright Coolers</u>	Check and clean coils, power cables, thermostats, motors, compressors, etc.
<u>Upright Freezers</u>	Check and clean coils, power cables, thermostats, motors, compressors, etc.
<u>Lowboy Coolers</u>	Check and clean coils, power cables, thermostats, motors, compressors, etc.
<u>Lowboy Freezers</u>	Check and clean coils, power cables, thermostats, motors, compressors, etc.
<u>Backroom Coolers</u>	Check and clean coils, power cables, thermostats, motors, compressors, etc.
<u>Backroom Freezers</u>	Check and clean coils, power cables, thermostats, motors, compressors, etc.
<u>Convection Oven</u>	Calibrate temperature, check latch and handle, check fan and proper airflow
<u>Bun Toaster</u>	Check drive chain tension, teflon sheets, heaters panel
<u>Hatco Warmer</u>	Calibrate Temperature, check door and handle, check fan and proper airflow
<u>Water Filters</u>	Check 110 prefilter, differential pressures, IMF inhibitor, leaks, and test alarm
<u>Cabinet Hinges</u>	Check all hinges on all cabinets fix as needed
<u>Caulking around fountain</u>	Check caulking around fountain, recaulk as needed
<u>Restroom Fans</u>	Check and clean motors, fan assembly, and balance as needed, etc.
<u>Exhaust Fan Motors on Roof</u>	Check and clean motors, fan assembly, and balance as needed, etc.
<u>Fly Fans</u>	Check and clean motors, fan assembly, and balance as needed, etc.

The completion of "ALL P.M. Maintenance" by the technician must be conducted according to the manufacturers specifications and recommendations. The outlined tasks above must be done in addition to any other outlined P.M. procedures.